

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12204-28-AM
Monitoring Date: 3/11/2020
Received Date: 3/11/2020
Analysis Date: 3/11/2020
Report Date: 4/11/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Jake Gunns
Approved Counter: Jake Gunns
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12204/198	Helipad, exclusion zone, north-western corner	1	08:15	14:29	2.02	2.02	0	100	<0.01
40-12204/199	Helipad, exclusion zone, eastern section	1	08:16	14:30	2.02	2.02	0	100	<0.01
40-12204/200	Helipad, exclusion zone, north-eastern corner	1	08:17	14:31	2.02	2.02	0	100	<0.01
40-12204/201	Helipad, exclusion zone, southern side of vehicle entryway	1	08:20	14:34	2.02	2.02	0	100	<0.01
40-12204/202	Helipad, exclusion zone, south-western corner	1	08:21	14:36	2.02	2.02	1	100	<0.01
40-12204/203	Helipad, exclusion zone, on fencing opposite decontamination clean exit	1	08:22	14:37	2.02	2.02	0	100	<0.01
40-12204/204	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12204-28-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12204-30-AM
Monitoring Date: 6/11/2020
Received Date: 6/11/2020
Analysis Date: 6/11/2020
Report Date: 6/11/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Jake Gunns
Approved Counter: Jake Gunns
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12204/212	Helipad, exclusion zone, north-western corner	1	07:00	14:17	1.04	1.04	0	100	<0.01
40-12204/213	Helipad, exclusion zone, eastern section	1	07:01	14:18	1.04	1.04	0	100	<0.01
40-12204/214	Helipad, exclusion zone, north-eastern corner	1	07:02	14:19	1.04	1.04	0	100	<0.01
40-12204/215	Helipad, exclusion zone, southern side of vehicle entryway	1	07:03	14:22	1.04	1.04	0	100	<0.01
40-12204/216	Helipad, exclusion zone, south-western corner	1	07:04	14:23	1.04	1.04	0	100	<0.01
40-12204/217	Helipad, exclusion zone, on fencing opposite decontamination clean exit	1	07:05	14:24	1.04	1.04	0	100	<0.01
40-12204/218	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12204-30-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12744-01-AM
Monitoring Date: 10/12/2020
Received Date: 10/12/2020
Analysis Date: 10/12/2020
Report Date: 11/12/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Nick Chongsun
Sampled By: Jake Gunns
Approved Counter: Jake Gunns
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12744/1	West entryway, adjacent decon	1	07:00	14:33	1.04	1.04	0	100	<0.01
40-12744/2	West entryway, north-western corner	1	07:01	14:35	1.04	1.04	0	100	<0.01
40-12744/3	West entryway, northern exclusion zone fence	1	07:02	14:38	1.04	1.04	0	100	<0.01
40-12744/4	West entryway, eastern exclusion zone fence	1	07:03	14:40	1.04	1.04	0	100	<0.01
40-12744/5	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12744-01-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12541-15-AM
Monitoring Date: 10/12/2020
Received Date: 10/12/2020
Analysis Date: 10/12/2020
Report Date: 11/12/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Jake Gunns
Approved Counter: Jake Gunns
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12541/71	Reclaimed area, service trenching, exclusion zone, northern fence, central section	1	08:16	14:47	2.02	2.02	1	100	<0.01
40-12541/72	Reclaimed area, service trenching, exclusion zone, southern fence, central section	1	08:17	14:48	2.02	2.02	0	100	<0.01
40-12541/73	Reclaimed area, service trenching, exclusion zone, western fence, central section	1	08:18	14:49	2.02	2.02	0	100	<0.01
40-12541/74	Reclaimed area, service trenching, exclusion zone, eastern fence, central section	1	08:19	14:50	2.02	2.02	0	100	<0.01
40-12541/75	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12541-15-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12541-12-AM
Monitoring Date: 20/11/2020
Received Date: 20/11/2020
Analysis Date: 20/11/2020
Report Date: 23/11/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Jake Gunns
Approved Counter: Jake Gunns
Approved Signatory: Nathan Crouch

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12541/56	Reclaimed area, service trenching, exclusion zone, northern fence, central section	1	07:00	14:29	1.04	1.04	1	100	<0.01
40-12541/57	Reclaimed area, service trenching, exclusion zone, southern fence, central section	1	07:01	14:30	1.04	1.04	0	100	<0.01
40-12541/58	Reclaimed area, service trenching, exclusion zone, western fence, central section	1	07:02	14:32	1.04	1.04	0	100	<0.01
40-12541/59	Reclaimed area, service trenching, exclusion zone, eastern fence, central section	1	07:03	14:33	1.04	1.04	0	100	<0.01
40-12541/60	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12541-12-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12541-13-AM
Monitoring Date: 23/11/2020
Received Date: 23/11/2020
Analysis Date: 23/11/2020
Report Date: 23/11/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Jake Gunns
Approved Counter: Jake Gunns
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12541/61	Reclaimed area, service trenching, exclusion zone, northern fence, central section	1	07:01	14:42	1.04	1.04	0	100	<0.01
40-12541/62	Reclaimed area, service trenching, exclusion zone, southern fence, central section	1	07:03	14:44	1.04	1.04	0	100	<0.01
40-12541/63	Reclaimed area, service trenching, exclusion zone, western fence, central section	1	07:05	14:45	1.04	1.04	0	100	<0.01
40-12541/64	Reclaimed area, service trenching, exclusion zone, eastern fence, central section	1	07:07	14:46	1.04	1.04	0	100	<0.01
40-12541/65	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12541-13-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12541-14-AM
Monitoring Date: 24/11/2020
Received Date: 24/11/2020
Analysis Date: 24/11/2020
Report Date: 24/11/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Jake Gunns
Approved Counter: Jake Gunns
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12541/66	Reclaimed area, service trenching, exclusion zone, northern fence, central section	1	07:00	14:45	1.02	1.02	0	100	<0.01
40-12541/67	Reclaimed area, service trenching, exclusion zone, southern fence, central section	1	07:01	14:47	1.02	1.02	0	100	<0.01
40-12541/68	Reclaimed area, service trenching, exclusion zone, western fence, central section	1	07:02	14:48	1.02	1.02	0	100	<0.01
40-12541/69	Reclaimed area, service trenching, exclusion zone, eastern fence, central section	1	07:03	14:50	1.02	1.02	1	100	<0.01
40-12541/70	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12541-14-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.