

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12204-21-AM
Monitoring Date: 1/10/2020
Received Date: 1/10/2020
Analysis Date: 1/10/2020
Report Date: 1/10/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Gonzalo Serna Diaz
Approved Counter: Jake Gunns
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12204/141	Helipad, exclusion zone, north-western corner	1	07:00	14:28	0.97	0.97	0	100	<0.01
40-12204/142	Helipad, exclusion zone, eastern section	1	07:01	14:29	0.97	0.97	0	100	<0.01
40-12204/143	Helipad, exclusion zone, north-eastern corner	1	07:02	14:30	0.97	0.97	0	100	<0.01
40-12204/144	Helipad, exclusion zone, southern side of vehicle entryway	1	07:03	14:34	0.97	0.97	0	100	<0.01
40-12204/145	Helipad, exclusion zone, south-western corner	1	07:04	14:35	0.97	0.97	0	100	<0.01
40-12204/146	Helipad, exclusion zone, on fencing opposite decontamination clean exit	1	07:05	14:36	0.97	0.97	0	100	<0.01
40-12204/147	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12204-21-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12204-22-AM
Monitoring Date: 2/10/2020
Received Date: 2/10/2020
Analysis Date: 2/10/2020
Report Date: 2/10/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Jake Gunns
Approved Counter: Gonzalo Serna Diaz
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12204/148	Helipad, exclusion zone, north-western corner	1	07:00	12:30	2.05	2.05	0	100	<0.01
40-12204/149	Helipad, exclusion zone, eastern section	1	07:01	12:32	2.05	2.05	1	100	<0.01
40-12204/150	Helipad, exclusion zone, north-eastern corner	1	07:02	12:34	2.05	2.05	0	100	<0.01
40-12204/151	Helipad, exclusion zone, southern side of vehicle entryway	1	07:03	12:35	2.05	2.05	1	100	<0.01
40-12204/152	Helipad, exclusion zone, south-western corner	1	07:04	12:36	2.05	2.05	1	100	<0.01
40-12204/153	Helipad, exclusion zone, on fencing opposite decontamination clean exit	1	07:05	12:38	2.05	2.05	0	100	<0.01
40-12204/154	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12204-22-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12204-23-AM
Monitoring Date: 7/10/2020
Received Date: 7/10/2020
Analysis Date: 7/10/2020
Report Date: 7/10/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Jake Gunns
Approved Counter: Jake Gunns
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12204/155	Helipad, exclusion zone, north-western corner	1	06:58	14:36	1.04	1.04	0	100	<0.01
40-12204/156	Helipad, exclusion zone, eastern section	1	06:59	14:37	1.04	1.04	0	100	<0.01
40-12204/157	Helipad, exclusion zone, north-eastern corner	1	07:00	14:38	1.04	1.04	0	100	<0.01
40-12204/158	Helipad, exclusion zone, southern side of vehicle entryway	1	07:04	14:42	1.04	1.04	0	100	<0.01
40-12204/159	Helipad, exclusion zone, south-western corner	1	07:05	14:43	1.04	1.04	0	100	<0.01
40-12204/160	Helipad, exclusion zone, on fencing opposite decontamination clean exit	1	07:06	14:44	1.04	1.04	0	100	<0.01
40-12204/161	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12204-23-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12541-01-AM
Monitoring Date: 15/10/2020
Received Date: 15/10/2020
Analysis Date: 15/10/2020
Report Date: 15/10/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Jake Gunns
Approved Counter: Jake Gunns
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Fibre Count checked by Luke Heckenberg.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12541/1	Reclaimed area, service trenching, exclusion zone, northern fence, central section	1	07:00	14:29	1.04	1.04	1	100	<0.01
40-12541/2	Reclaimed area, service trenching, exclusion zone, southern fence, central section	1	07:01	14:30	1.04	1.04	1	100	<0.01
40-12541/3	Reclaimed area, service trenching, exclusion zone, western fence, central section	1	07:02	14:32	1.04	1.04	0	100	<0.01
40-12541/4	Reclaimed area, service trenching, exclusion zone, eastern fence, central section	1	07:03	14:33	1.04	1.04	0	100	<0.01
40-12541/5	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12541-01-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12541-02-AM
Monitoring Date: 16/10/2020
Received Date: 16/10/2020
Analysis Date: 16/10/2020
Report Date: 16/10/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Jake Gunns
Approved Counter: Jake Gunns
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12541/6	Reclaimed area, service trenching, exclusion zone, northern fence, central section	1	07:00	14:35	1.04	1.04	1	100	<0.01
40-12541/7	Reclaimed area, service trenching, exclusion zone, southern fence, central section	1	07:01	14:37	1.04	1.04	0	100	<0.01
40-12541/8	Reclaimed area, service trenching, exclusion zone, western fence, central section	1	07:02	14:40	1.04	1.04	0	100	<0.01
40-12541/9	Reclaimed area, service trenching, exclusion zone, eastern fence, central section	1	07:03	14:42	1.04	1.04	1	100	<0.01
40-12541/10	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12541-02-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12541-03-AM
Monitoring Date: 19/10/2020
Received Date: 19/10/2020
Analysis Date: 19/10/2020
Report Date: 19/10/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Jake Gunns
Approved Counter: Jake Gunns
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12541/11	Reclaimed area, service trenching, exclusion zone, northern fence, central section	1	06:59	14:21	1.04	1.04	1	100	<0.01
40-12541/12	Reclaimed area, service trenching, exclusion zone, southern fence, central section	1	07:01	14:23	1.04	1.04	0	100	<0.01
40-12541/13	Reclaimed area, service trenching, exclusion zone, western fence, central section	1	07:03	14:25	1.04	1.04	0	100	<0.01
40-12541/14	Reclaimed area, service trenching, exclusion zone, eastern fence, central section	1	07:05	14:27	1.04	1.04	1	100	<0.01
40-12541/15	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12541-03-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12541-05-AM
Monitoring Date: 21/10/2020
Received Date: 21/10/2020
Analysis Date: 21/10/2020
Report Date: 21/10/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Jake Gunns
Approved Counter: Jake Gunns
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12541/21	Reclaimed area, service trenching, exclusion zone, northern fence, central section	1	07:00	14:29	1.04	1.04	0	100	<0.01
40-12541/22	Reclaimed area, service trenching, exclusion zone, southern fence, central section	1	07:01	14:31	1.04	1.04	0	100	<0.01
40-12541/23	Reclaimed area, service trenching, exclusion zone, western fence, central section	1	07:02	14:32	1.04	1.04	0	100	<0.01
40-12541/24	Reclaimed area, service trenching, exclusion zone, eastern fence, central section	1	07:03	14:35	1.04	1.04	1	100	<0.01
40-12541/25	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12541-05-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12541-06-AM
Monitoring Date: 22/10/2020
Received Date: 22/10/2020
Analysis Date: 22/10/2020
Report Date: 22/10/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Jake Gunns
Approved Counter: Jake Gunns
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12541/26	Reclaimed area, service trenching, exclusion zone, northern fence, central section	1	07:00	15:00	1.04	1.04	1	100	<0.01
40-12541/27	Reclaimed area, service trenching, exclusion zone, southern fence, central section	1	07:01	15:02	1.04	1.04	0	100	<0.01
40-12541/28	Reclaimed area, service trenching, exclusion zone, western fence, central section	1	07:02	15:03	1.04	1.04	0	100	<0.01
40-12541/29	Reclaimed area, service trenching, exclusion zone, eastern fence, central section	1	07:03	15:05	1.04	1.04	0	100	<0.01
40-12541/30	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12541-06-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-12541-08-AM
Monitoring Date: 30/10/2020
Received Date: 30/10/2020
Analysis Date: 30/10/2020
Report Date: 2/11/2020
Site Address: Concord Repatriation Hospital,
 Hospital Road
 Concord NSW 2139
Client Name: N. Moit & Sons (NSW) Pty. Ltd.
Client Address: 142 Wicks Road
 Macquarie Park NSW 2113

Client Contact: Omar Ghanem
Sampled By: Jake Gunns
Approved Counter: Jake Gunns
Approved Signatory: Luke Heckenberg

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-12541/36	Reclaimed area, service trenching, exclusion zone, northern fence, central section	1	07:00	14:18	1.04	1.04	0	100	<0.01
40-12541/37	Reclaimed area, service trenching, exclusion zone, southern fence, central section	1	07:01	14:19	1.04	1.04	0	100	<0.01
40-12541/38	Reclaimed area, service trenching, exclusion zone, western fence, central section	1	07:02	14:20	1.04	1.04	0	100	<0.01
40-12541/39	Reclaimed area, service trenching, exclusion zone, eastern fence, central section	1	07:03	14:21	1.04	1.04	0	100	<0.01
40-12541/40	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-12541-08-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.